

APPENDIX L

**Suffolk County Department of Health Services Notice
April 13, 2016**

SUFFOLK COUNTY DEPARTMENT OF HEALTH SERVICES
 OFFICE OF WASTEWATER MANAGEMENT
 360 YAPHANK AVENUE, SUITE 2C
 YAPHANK, NEW YORK 11980
 (631) 852-5700

NOTICE 5
 GMZ 4

NOTICE OF INCOMPLETE APPLICATION – SUBDIVISION

TO: Mr. John Ehlers, L.S. 6 East Main Street Riverhead, N.Y. 11901	SUB NAME: THE ORCHARDS REF. NO.: S10-13-0005 SCTM NO: 1000-27-01-03
--	---

Your submission for the referenced subdivision has been reviewed. This office will require the following for further review and/or approval:

- Application form signed by licensed design professional
- Yield map, minimum _____ square foot lots. Filing fee \$ _____ due.
- Test hole(s) located and witnessed by:
 - Health Dept.-Call 852-5754 to schedule inspection. See location map enclosed.
- Test well(s) sampled by Health Department. Follow procedures enclosed. (Test well does **not** indicate a waiver of requirement for connection to public water) - see location map enclosed.
- Public water availability letter from water district (Include distance & cost if water main extension is required).
- Short Environmental Assessment Form (enclosed). Wetlands permit or determination letter.
- Design report by licensed design professional for the onsite sewage disposal system and water supply.
- Covenants: TBD.
- Board of Review variance. Non-conformance notice enclosed.
- SEQRA determination from Town. Certificate of Authorization, or disclaimer.

In addition, the following is required to be shown on a preliminary/final map or on a separate sewage disposal/water supply plan signed and sealed by a licensed design professional:

- Metes and Bounds Description* Suffolk County Tax Map Number*
- Sewage disposal & water supply locations for all existing buildings on property (specify if none)
- Neighboring wells and sewage disposal systems within 150 feet of property (specify if none)
- Design for the onsite sewage disposal and water supply per Department standards
- Design for sewer main extension approved by local sewer district (for existing sewers in Sewer District#3, sewer stubs must be marked by district on plan) Topographic contours. (5 ft. interval)
- Water/Sewer main location(s) (label as existing/proposed)* Test well locations*
- Corner elevations and test hole elevation Department approval stamp*
- Test hole location(s)/details* Typical lot layout: water & sewage disposal*
- L.S. certification and certification of sewage disposal & water supply design by P.E., R.A., or L.S. with exemption (original signatures & seals required)*.

[*] **FINAL** maps to be filed with County Clerk require items marked above with asterisk (*).

Other: (1) Submit copy of Conservation Easement. (2) Label Future Barn area as " Lot # 1 location of Future Agricultural Barn.....". (3) After reviewing Test Well --Test results and Well Drillers Cert. showing less than 40 feet of water in each well, this Subdivision will require each proposed lot to be at least 2 acres, if this requirement cannot be met a Board of Review variance will be required.

CC: Mr. Steven A. Martocello
 24 Miller Woods Drive
 Miller Place, N.Y. 11764

REVIEWED BY: J.T.McGuire
DATE: 13 April 2016